

PROVEN METHODOLOGY SPEEDS REPAIR OF OIL, NITROGEN OR SF6 GAS LEAKS

By Gary Lee Brown and Jim Hackett

Dielectric fluid, nitrogen and SF-6 gas leaks have plagued the electric industry for years. In the past, it was common practice to take leaking equipment out of service, drain the oil, re-gasket all potential leak points, re-fill the unit and hope that the problems were corrected. In some cases a leak would re-occur and the whole process was then repeated.

Today these leaks can be repaired without draining or de-pressurizing the equipment by means of hydraulically injecting compatible sealants to stop the leak. Colt Atlantic Services, Inc. has been providing on-line leak sealing services to a wide range of industries for over twenty years. Their Power Services Division has a highly experienced staff




Figure 1



Figure 2



Figure 3

that is dedicated to repairing oil and gas leaks on electrical equipment.

The repair process varies depending on the type of leak, but a typical leak is found around the stem area of the radiator flapper valve. If the leak is located low enough on the transformer, the repair is completed with the unit in service, and in all cases the repairs are com-

pleted without draining the transformer. To repair a stem leak, the technician will drill and tap a 1/16" blind hole into the side of the valve at a point that will intersect the internal O-rings or rope packing. Next, they will install an injector into the tapped hole. This injector allows the technician to control any oil flow that may occur during the next step. Using a 1/8" drill bit he will then insert the drill into the injector and drill a hole into the seal area. The bit is then removed and the injector is turned to the closed position. A proprietary, two-part compound is then hydraulically injected into the seal area. The material is allowed to cure, typically for one hour. The injector is then removed and a Teflon coated pipe plug is installed. An independent lab has tested our S-22 Sealant for dielectric properties and dissolved gas analysis. This material is not an epoxy and will not bond to the equipment. This allows for easy disassembly of the repaired component at a later time. The sealant also has a memory that will allow it to expand and contract without cracking, during temperature changes and vibration.

The following are case studies of different leak sealing jobs and/or devices and their uses:

Figure 1 and 2 show a type of clamp used frequently on radiator drain plugs. It is designed to close on the half coupling OD. The crunch teeth (see Figure 2) are designed to have a .005 to .010 interference fit. The teeth wipe out around the half coupling OD creating a barrier for our sealant to bridge up against during the injection process. The aluminum clamps are just tapped on with

REACH & RELIABILITY FIRST TIME, EVERY TIME

See **NEW**
100-ft. Insulated
Model at
ICUEE

Bronto aerials provide a safer way to reach overhead areas. They're ready to work when you are, and they're more versatile, more maneuverable, and more productive than any other product on the market today.

- Insulated and non-insulated models available
- Working heights to 236 feet
- Horizontal reach to over 102 feet
- Platform capacities to 1500 lbs.
- Integrated insulator washing system available

In Canada call:
HYCOTEC, INC.
905 / 309-5111

Outside Canada call:
BRONTO SKYLIFT
352 / 895-1109

www.bronto.fi

